

电气运行日报表

年 月 日

项目 时间	1#发电机													10kV 4-9				厂变电流			直流系统			UPS	
	A相电压	B相电压	C相电压	线电压	A定子电 流	B定子电 流	C定子电 流	频率	有功 功率	无功 功率	功率 因数	励磁 电压	励磁 电流	A相电压	B相电压	C相电压	线电压	1#厂变	2#厂变	烟气变	母线电压	负载电流	浮充电压	输入电压	输出电压
	KV	KV	KV	KV	A	A	A	HZ	KW	KVAR	%	V	A	KV	KV	KV	KV	A	A	A	V	A	V	V	V
标准值	6	6	6	10.5	550	550	550	50	8000		0.9	320	220	6	6	6	10.5	2300	2300	1800	220		220	220	220
2																									
4																									
6																									
8																									
10																									
12																									
14																									
16																									
18																									
20																									
22																									
24																									
夜班	值别:		记录人:					时间:					备注:												
白班	值别:		记录人:					时间:																	
中班	值别:		记录人:					时间:																	

年 月 日

	项目	1#发电机													10kV 4-9				厂变电流			直流系统			UPS	
		A相电压	B相电压	C相电压	线电压	A定子电 流	B定子电 流	C定子电 流	频率	有功 功率	无功 功率	功率 因数	励磁 电压	励磁 电流	A相电压	B相电压	C相电压	线电压	1#厂变	2#厂变	烟气变	母线电压	负载电流	浮充电压	输入电压	输出电压
时间		KV	KV	KV	KV	A	A	A	HZ	KW	KVAR	%	V	A	KV	KV	KV	KV	A	A	A	V	A	V	V	V
标准值		6	6	6	10.5	550	550	550	50	8000		0.9	320	220	6	6	6	10.5	2300	2300	1800	220		220	220	220
2																										
4																										
6																										
8																										
10																										
12																										
14																										
16																										
18																										
20																										
22																										
24																										
夜班		值别:		记录人:					时间:					备注:												
白班		值别:		记录人:					时间:																	
中班		值别:		记录人:					时间:																	